

SOPEMEA SAS Groupe APAVE
Laboratoire de Conformité Electrique
27 Rue de l'avenir,
FR-69740 Genas FRANCE

nVent
Jules Verneweg 75

5015 BG TILBURG THE NETHERLANDS

A l'attention de / To : Mr Dennis DINGEMANS

**DOCUMENT DE SYNTHESE /
SYNTHESIS DOCUMENT**

**EVALUATION DE CONFORMITE DES BARRES ISOLEES ERIFLEX MODELE ERIFLEX
FLEXIBAR ADVANCED / CONFORMITY ASSESSMENT OF ERIFLEX INSULATED BUSBAR, TYPE
ERIFLEX FLEXIBAR ADVANCED**
1E45501BT-03 REV.0

1. PORTEE DE CE DOCUMENT / SCOPE OF THIS DOCUMENT

Le présent document constitue la synthèse du rapport **SOPEMEA 1E45501BT-01 REV.0** qui donne le détail des résultats des contrôles et réalisés sur le produit / The present document constitutes the synthesis of the report **SOPEMEA 1E45501BT-01 REV.0**. which gives the details of inspections and test achieved on the product.

2. PRODUIT CONCERNE / CONCERNED PRODUCT

Echantillon testé: <i>Test item:</i>	BARRES FLEXIBLES ISOLEES / FLEXIBLE INSULATED BUSBAR	Tension nominale <i>Rated voltage</i>	1000VAC / 1500 VDC
Marque: <i>Trade Mark</i>	ERICO nVent	Régime de neutre (classe II) <i>Neutral position (Class II)</i>	All
Identification / Typ-No: <i>Identification / Type No.:</i>	ERIFLEX FLEXIBAR ADVANCED	Numéro de série <i>Serial number</i>	/

3. OBJECTIF DE LA MISSION / SCOPE OF THE MISSION (voir les détails dans le rapport / See details in test report)

Spécification(s) de test:
Test specification: Evaluation de la conformité du produit et de son dossier technique aux documents suivants : / *Conformity assessment of the product and its technical file to the following documents :*
IEC 61439-2:2020 for use in conjunction with IEC 61439-1:2020

4. CONCLUSION DU RAPPORT / TEST REPORT CONCLUSION

La conclusion du rapport montre que le produit examine est conforme aux prescription de (des) documents(s) de reference. / *The conclusion of the test report shows that the examined product comply with the prescriptions of the reference documents.*

S MANDRAY / Ingénieur Conformité
19/01/2026
Limite de validité / Limit of validity : 3 ans / 3 years

