

SYNTHESIS DOCUMENT
CONFORMITY ASSESSMENT OF ERIFLEX INSULATED
BUSBAR, TYPE ERIFLEX FLEXIBAR ADVANCED

1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 9533892-001-1 which gives the details of inspections and tests achieved on the product.

2 CONCERNED PRODUCT **SPECIFIED FEATURE**

- | | | | |
|-----------------|------------------------------|-----------------------------------|---------------------------------|
| • Designation : | FLEXIBLE INSULATED
BUSBAR | • Rated voltage : | 1000 V |
| • Make : | ERICO PENTAIR | • Neutral position
(class II): | TN and TT - 830 V
IT - 600 V |
| • Model : | ERIFLEX FLEXIBAR
ADVANCED | • Serial number : | / |

3 SCOPE OF THE MISSION (to see details in report)

Conformity Assessment of the product and its technical file to the following documents :

⇒ IEC 61439-2: 2011 use in conjunction with IEC 61439-1: 2011 .

CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

Tassin the 27/07/2017

Technical Manager of the test laboratory

Document original immatériel



Xavier SCHMITT

Limit of validity of this document : 5 years