



APAVE SUDEUROPE SAS
LABORATOIRE DE LYON TASSIN
Accredited body by COFRAC n° 1-1461

Essais Sur Produits
177, route de Sain-Bel

69160 TASSIN LA DEMI-LUNE

ERICO
B.P 31
Rue Charles Dallièrè
42161 ANDREZIEUX
BOUTHEON

SYNTHESIS DOCUMENT

CONFORMITY ASSESSMENT

1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 6943931-001-1 which gives the details of inspections and tests achieved on the range of product.

2 CONCERNED PRODUCT

- Name : Range of insulators
- Designation : /
- Make : ERICO
- Model : ERIFLEX ISO-TP

SPECIFIED FEATURE

- Voltage : 500Vac or 1000Vac /
500Vdc or 1500Vdc
- Neutral position : all
- Serial number : /

3 SCOPE OF THE MISSION (to see details in report)

Conformity Assessment of the range of product and its technical file to the following documents :

⇒ NF EN 61439-1 – March 2012

CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

Tassin the 11/6/2012

The Manager of the test laboratory

Document original immatériel

Xavier SCHMITT

Limit of validity of this document : 5 years

This document is not a report established under the title of a Notified body, it is a synthesis of the mission achieved by APAVE and only the complete French report maybe used as reference. It doesn't substitute itself to the DECLARATION OF CONFORMITY issued by the manufacturer, according the market regulation of the EUROPEAN UNION and cannot be use as a guarantee of the production conformity to the type.
Its reproduction is only allowed as a complete photographic facsimile